



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

VLI-880, VLI-885. VESDA VLI Aspirating Smoke Detector

NI/II/2/ABCD/T6 Ta = 0°C to 49°C; IP54

Special Condition of Use;

1. The apparatus is to be powered by the VPS-100US Power Supply.

Equipment Ratings:

Nonincendive for class I, Division 2, Groups A, B, C and D, hazardous (Classified) locations.

FM Approved for:

Xtralis Inc
Norwell, MA United States



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM3600	2011
FM3611	2004
FM3810	2005
ANSI/IEC 60529	2004

Original Project ID: 3046852

Approval Granted: December 27, 2012

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

A handwritten signature in black ink, appearing to read "J.E. Marquedant".

J.E. Marquedant
Group Manager, Electrical

27 December 2012

Date